



PRODUKTDEKLARATION

LJUDABSORPTIONSAREA FÖR OBJEKT

Mätt och utvärderad enligt ISO 354 och ISO 20189


Producent:	Abstracta
Objekt:	Scala XL (concave not upholstered)
Storlek [mm]:	w=90 h=2300 d=1183

Ekvivalent ljudabsorptionsarea per objekt (m² Sabine)

f(Hz)	Tersband	Oktavband
100	0.11	
125	0.27	0.24
160	0.49	
200	0.66	
250	1.08	0.94
315	1.09	
400	1.47	
500	2.28	2.07
630	2.48	
800	2.49	
1000	2.73	2.70
1250	2.87	
1600	2.89	
2000	3.25	3.06
2500	3.02	
3150	3.32	
4000	3.44	3.52
5000	3.80	

N₁₀ = 4.8

Ekvivalent ljudabsorptionsarea per objekt



ORIGINAL TESTRAPPORT	RAPPORTDATUM
20210128.3	2023-04-21

