



## PRODUKTDEKLARATION

### LJUDABSORPTIONSAREA FÖR OBJEKT


Mätt och utvärderad enligt ISO 354 och ISO 20189

<b>Producent:</b>	Abstracta
<b>Objekt:</b>	Scala XL (concave upholstered with fabric)
<b>Storlek [mm]:</b>	w=90 h=2300 d=1183

#### Ekvivalent ljudabsorptionsarea per objekt (m<sup>2</sup> Sabine)

f(Hz)	Tersband	Oktavband
100	0.13	
125	0.31	0.36
160	0.79	
200	0.74	
250	1.08	1.10
315	1.50	
400	1.79	
500	2.14	2.18
630	2.60	
800	2.76	
1000	2.92	2.88
1250	2.96	
1600	3.11	
2000	3.17	3.14
2500	3.14	
3150	3.48	
4000	3.85	3.68
5000	3.71	

#### Ekvivalent ljudabsorptionsarea per objekt



N<sub>10</sub> = 4.6

ORIGINAL TESTRAPPORT	RAPPORTDATUM
20210128.3	2023-04-21

