



PRODUKTDEKLARATION

LJUDABSORPTIONSAREA FÖR OBJEKT


Mätt och utvärderad enligt ISO 354 och ISO 20189

Producent:	Abstracta
Objekt:	Scala XL (convex upholstered with fabric)
Storlek [mm]:	w=90 h=2300 d=1183

Ekvivalent ljudabsorptionsarea per objekt (m² Sabine)

f(Hz)	Tersband	Oktavband
100	0.47	
125	0.73	0.70
160	1.05	
200	1.19	
250	1.73	1.46
315	1.78	
400	2.07	
500	2.72	2.47
630	2.63	
800	2.39	
1000	2.76	2.74
1250	3.08	
1600	2.88	
2000	2.95	2.98
2500	3.11	
3150	3.45	
4000	3.78	3.64
5000	3.68	

Ekvivalent ljudabsorptionsarea per objekt



N₁₀ = 4

ORIGINAL TESTRAPPORT	RAPPORTDATUM
20210128.3	2023-04-21

