



PRODUKTDEKLARATION

LJUDABSORPTIONSAREA FÖR OBJEKT


Mätt och utvärderad enligt ISO 354 och ISO 20189

Producent:	Abstracta
Objekt:	Softline 50 Table
Storlek [mm]:	w=50 h=650 d=600

Ekvivalent ljudabsorptionsarea per objekt (m² Sabine)

f(Hz)	Tersband	Oktavband
50	0.04	
63	0.07	0.10
80	0.13	
100	0.06	
125	0.14	0.10
160	0.12	
200	0.29	
250	0.31	0.30
315	0.32	
400	0.46	
500	0.49	0.50
630	0.64	
800	0.68	
1000	0.62	0.60
1250	0.64	
1600	0.61	
2000	0.61	0.60
2500	0.61	
3150	0.66	
4000	0.61	0.70
5000	0.69	

Ekvivalent ljudabsorptionsarea per objekt



N₁₀ = 19

ORIGINAL TESTRAPPORT

15-065-M4

RAPPORTDATUM

2016-08-15

