



## PRODUKTDEKLARATION

### LJUDABSORPTIONSAREA FÖR OBJEKT


Mätt och utvärderad enligt ISO 354 och ISO 20189

<b>Producent:</b>	Abstracta
<b>Objekt:</b>	Soneo Wall
<b>Storlek [mm]:</b>	w=30 h=1000 d=1000

#### Ekvivalent ljudabsorptionsarea per objekt (m<sup>2</sup> Sabine)

f(Hz)	Tersband	Oktavband
50	0.02	
63	0.02	0.01
80	0.07	
100	0.09	
125	0.18	0.14
160	0.18	
200	0.25	
250	0.33	0.12
315	0.48	
400	0.59	
500	0.81	0.25
630	0.87	
800	0.93	
1000	1.00	0.32
1250	0.97	
1600	0.99	
2000	1.07	0.34
2500	0.98	
3150	1.13	
4000	1.01	0.37
5000	1.15	

#### Ekvivalent ljudabsorptionsarea per objekt



N<sub>10</sub> = 13

ORIGINAL TESTRAPPORT

17-360-M6

RAPPORTDATUM

2018-01-23

