



PRODUKTDEKLARATION

LJUDABSORPTIONSAREA FÖR OBJEKT


Mätt och utvärderad enligt ISO 354 och ISO 20189

Producent:	Abstracta
Objekt:	Soneo Wall
Storlek [mm]:	w=30 h=1000 d=1000

Ekvivalent ljudabsorptionsarea per objekt (m² Sabine)

f(Hz)	Tersband	Oktavband
50	0.02	
63	0.02	0.01
80	0.07	
100	0.09	
125	0.18	0.14
160	0.18	
200	0.25	
250	0.33	0.12
315	0.48	
400	0.59	
500	0.81	0.25
630	0.87	
800	0.93	
1000	1.00	0.32
1250	0.97	
1600	0.99	
2000	1.07	0.34
2500	0.98	
3150	1.13	
4000	1.01	0.37
5000	1.15	

Ekvivalent ljudabsorptionsarea per objekt



N₁₀ = 13

ORIGINAL TESTRAPPORT

17-360-M6

RAPPORTDATUM

2018-01-23

