



PRODUKTDEKLARATION

LJUDABSORPTIONSAREA FÖR OBJEKT

Mätt och utvärderad enligt ISO 354 och ISO 20189


Producent:	Glimakra Of Sweden
Objekt:	Limbus Concept Workstation
Storlek [mm]:	w=1600 h=1600 d=1260

Ekvivalent ljudabsorptionsarea per objekt (m² Sabine)

f(Hz)	Tersband	Oktavband
50	1.17	
63	1.66	1.36
80	1.25	
100	2.41	
125	2.41	2.35
160	2.23	
200	2.23	
250	2.67	2.71
315	3.23	
400	3.76	
500	4.26	4.48
630	5.43	
800	6.56	
1000	7.33	7.32
1250	8.08	
1600	8.73	
2000	8.77	8.77
2500	8.80	
3150	8.98	
4000	8.79	8.98
5000	9.18	

N₁₀ = 2.2

Ekvivalent ljudabsorptionsarea per objekt



ORIGINAL TESTRAPPORT	RAPPORTDATUM
sp report 10188024.3	2013-11-04

