



## PRODUKTDEKLARATION

### LJUDABSORPTIONSAREA FÖR OBJEKT

Mätt och utvärderad enligt ISO 354 och ISO 20189


<b>Producent:</b>	Glimakra Of Sweden
<b>Objekt:</b>	Limbus Concept Workstation
<b>Storlek [mm]:</b>	w=1600 h=1600 d=1260

#### Ekvivalent ljudabsorptionsarea per objekt (m<sup>2</sup> Sabine)

f(Hz)	Tersband	Oktavband
50	1.17	
63	1.66	1.36
80	1.25	
100	2.41	
125	2.41	2.35
160	2.23	
200	2.23	
250	2.67	2.71
315	3.23	
400	3.76	
500	4.26	4.48
630	5.43	
800	6.56	
1000	7.33	7.32
1250	8.08	
1600	8.73	
2000	8.77	8.77
2500	8.80	
3150	8.98	
4000	8.79	8.98
5000	9.18	

N<sub>10</sub> = 2.2

#### Ekvivalent ljudabsorptionsarea per objekt



ORIGINAL TESTRAPPORT	RAPPORTDATUM
sp report 10188024.3	2013-11-04

