



PRODUKTDEKLARATION

LJUDABSORPTIONSAREA FÖR OBJEKT


Mätt och utvärderad enligt ISO 354 och ISO 20189

Producent:	Glimakra Of Sweden
Objekt:	Wannabetree No. 6
Storlek [mm]:	w=560 h=2085 d=1235

Ekvivalent ljudabsorptionsarea per objekt (m² Sabine)

f(Hz)	Tersband	Oktavband
50	0.12	
63	0.15	0.12
80	0.08	
100	0.17	
125	0.34	0.30
160	0.40	
200	0.51	
250	0.78	0.76
315	1.00	
400	1.37	
500	1.75	1.74
630	2.10	
800	2.61	
1000	3.00	2.93
1250	3.18	
1600	3.52	
2000	3.51	3.47
2500	3.37	
3150	3.50	
4000	3.37	3.46
5000	3.52	

Ekvivalent ljudabsorptionsarea per objekt



N₁₀ = 5.7

ORIGINAL TESTRAPPORT	RAPPORTDATUM
SP report 10188024.2	2013-11-04

