



PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


Producer:	Abstracta
Object:	Vika lamp
Size [mm]:	w=283 h=155 d=1500

Equivalent sound absorption area per unit (m² Sabine)

f(Hz)	Octave Band
125	0.04
250	0.24
500	0.52
1000	0.70
2000	0.91
4000	0.80

N₁₀ = 19

Equivalent sound absorption area per unit



ORIGINAL TEST REPORT	DATE OF REPORT
-	-

