



PRODUKTDEKLARATION

LJUDABSORPTIONSAREA FÖR OBJEKT

Mätt och utvärderad enligt ISO 354 och ISO 20189


Producent:	Abstracta
Objekt:	Akunok Sofa 2 Seater
Storlek [mm]:	w=980 h=1290 d=1990

Ekvivalent ljudabsorptionsarea per objekt (m² Sabine)

f(Hz)	Tersband	Oktavband
100	2.67	
125	2.50	3.00
160	3.89	
200	4.21	
250	4.36	4.50
315	5.05	
400	6.10	
500	6.08	6.20
630	6.49	
800	6.59	
1000	6.56	6.70
1250	7.07	
1600	6.93	
2000	7.13	7.00
2500	6.93	
3150	7.09	
4000	7.11	6.70
5000	5.91	

N₁₀ = 1.6

Ekvivalent ljudabsorptionsarea per objekt



ORIGINAL TESTRAPPORT	RAPPORTDATUM
20231213.4	2023-12-18

