



## PRODUKTDEKLARATION

### LJUDABSORPTIONSAREA FÖR OBJEKT

Mätt och utvärderad enligt ISO 354 och ISO 20189


<b>Producent:</b>	Abstracta
<b>Objekt:</b>	Akunok Floor Screen
<b>Storlek [mm]:</b>	w=312 h=1610 d=1570

#### Ekvivalent ljudabsorptionsarea per objekt (m<sup>2</sup> Sabine)

f(Hz)	Tersband	Oktavband
100	1.35	
125	1.05	1.50
160	2.01	
200	2.17	
250	2.24	2.40
315	2.83	
400	3.18	
500	3.63	3.50
630	3.73	
800	3.71	
1000	4.02	4.00
1250	4.17	
1600	4.12	
2000	4.16	4.10
2500	4.08	
3150	4.01	
4000	3.87	3.80
5000	3.38	

N<sub>10</sub> = 2.8

#### Ekvivalent ljudabsorptionsarea per objekt



<b>ORIGINAL TESTRAPPORT</b>	<b>RAPPORTDATUM</b>
20231213.2	2023-12-18

