



PRODUKTDEKLARATION

LJUDABSORPTIONSAREA FÖR OBJEKT

Mätt och utvärderad enligt ISO 354 och ISO 20189

Producent: Götessons, Akustikmiljö / Am Acoustics

Objekt: PlantPanel (6 st)


Storlek [mm]: w=210 h=1160 d=1740

Ekvivalent ljudabsorptionsarea per objekt (m² Sabine)

f(Hz)	Tersband	Oktavband
50	0.09	
63	0.12	0.12
80	0.16	
100	0.23	
125	0.28	0.46
160	0.86	
200	1.03	
250	1.14	1.20
315	1.29	
400	1.57	
500	1.45	1.50
630	1.62	
800	1.93	
1000	1.90	1.90
1250	2.01	
1600	2.10	
2000	2.24	2.20
2500	2.17	
3150	2.25	
4000	2.24	2.20
5000	2.20	

N₁₀ = 6.5

Ekvivalent ljudabsorptionsarea per objekt



ORIGINAL TESTRAPPORT

RAPPORTDATUM

22-702-M5

2022-02-28

