



PRODUKTDEKLARATION

LJUDABSORPTIONSAREA FÖR OBJEKT

Mätt och utvärderad enligt ISO 354 och ISO 20189


Producent:	Götessons
Objekt:	ScreenIT A30
Storlek [mm]:	w=40 h=450 d=760

Ekvivalent ljudabsorptionsarea per objekt (m² Sabine)

f(Hz)	Tersband	Oktavband
50	0.06	
63	0.06	0.07
80	0.10	
100	0.11	
125	0.11	0.14
160	0.19	
200	0.27	
250	0.27	0.28
315	0.29	
400	0.27	
500	0.32	0.30
630	0.32	
800	0.40	
1000	0.40	0.39
1250	0.38	
1600	0.41	
2000	0.45	0.44
2500	0.46	
3150	0.46	
4000	0.50	0.50
5000	0.54	

N₁₀ = 33

Ekvivalent ljudabsorptionsarea per objekt



ORIGINAL TESTRAPPORT	RAPPORTDATUM
2629-R2	2022-12-06

