



PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


| | |
|-------------------|--------------------------|
| Producer: | Götessons |
| Object: | ScreenIT A30 Floor Scren |
| Size [mm]: | w=40 h=1200 d=800 |

Equivalent sound absorption area per unit (m² Sabine)

| f(Hz) | Octave Band |
|-------|-------------|
| 63 | 0.30 |
| 125 | 0.58 |
| 250 | 0.91 |
| 500 | 1.10 |
| 1000 | 1.20 |
| 2000 | 1.40 |
| 4000 | 1.50 |

N₁₀ = 9.1

Equivalent sound absorption area per unit



| | |
|-----------------------------|-----------------------|
| ORIGINAL TEST REPORT | DATE OF REPORT |
| - | - |

