



# PRODUCT DECLARATION

## SOUND ABSORPTION AREA FOR OBJECT


Measured and evaluated according to ISO 354 and ISO 20189

<b>Producer:</b>	Form2
<b>Object:</b>	Screen floor partition 40
<b>Size [mm]:</b>	w=40 h=1400 d=1400

### Equivalent sound absorption area per unit (m<sup>2</sup> Sabine)

f(Hz)	1/3 Octave Band	Octave Band
50	0.60	
63	0.30	0.38
80	0.25	
100	0.67	
125	0.70	0.91
160	1.36	
200	1.53	
250	1.58	1.60
315	1.62	
400	1.99	
500	2.37	2.40
630	2.85	
800	3.29	
1000	3.27	3.20
1250	3.23	
1600	3.41	
2000	3.41	3.40
2500	3.32	
3150	3.49	
4000	3.56	3.60
5000	3.63	

Equivalent sound absorption area per unit



N<sub>10</sub> = 4.2

<b>ORIGINAL TEST REPORT</b>	<b>DATE OF REPORT</b>
-	-

