



PRODUKTDEKLARATION

LJUDABSORPTIONSAREA FÖR OBJEKT

Mätt och utvärderad enligt ISO 354 och ISO 20189


Producent:	Form2
Objekt:	Screen Golvskärm 40
Storlek [mm]:	w=40 h=1400 d=1400

Ekvivalent ljudabsorptionsarea per objekt (m² Sabine)

f(Hz)	Tersband	Oktavband
50	0.60	
63	0.30	0.38
80	0.25	
100	0.67	
125	0.70	0.91
160	1.36	
200	1.53	
250	1.58	1.60
315	1.62	
400	1.99	
500	2.37	2.40
630	2.85	
800	3.29	
1000	3.27	3.20
1250	3.23	
1600	3.41	
2000	3.41	3.40
2500	3.32	
3150	3.49	
4000	3.56	3.60
5000	3.63	

N₁₀ = 4.2

Ekvivalent ljudabsorptionsarea per objekt



ORIGINAL TESTRAPPORT

RAPPORTDATUM

