



PRODUKTDEKLARATION

LJUDABSORPTIONSAREA FÖR OBJEKT


Mätt och utvärderad enligt ISO 354 och ISO 20189

Producent:	Form2
Objekt:	Screen Golvskärm 30
Storlek [mm]:	w=30 h=1400 d=1400

Ekvivalent ljudabsorptionsarea per objekt (m² Sabine)

f(Hz)	Tersband	Oktavband
50	0.43	
63	0.33	0.34
80	0.27	
100	0.50	
125	0.73	0.81
160	1.19	
200	1.36	
250	1.40	1.40
315	1.52	
400	1.74	
500	2.12	2.10
630	2.46	
800	2.81	
1000	2.92	3.00
1250	3.13	
1600	3.35	
2000	3.35	3.30
2500	3.25	
3150	3.44	
4000	3.43	3.50
5000	3.52	

Ekvivalent ljudabsorptionsarea per objekt



$N_{10} = 4.7$

ORIGINAL TESTRAPPORT

RAPPORTDATUM

