



PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT


Measured and evaluated according to ISO 354 and ISO 20189

| | |
|-------------------|------------------------------------------------|
| Producer: | Form2 |
| Object: | Kompad screen 40 |
| Size [mm]: | w=40 h=650 d=1200 Total Construction Height=40 |

Equivalent sound absorption area per unit (m² Sabine)

| f(Hz) | 1/3 Octave Band | Octave Band |
|-------|-----------------|-------------|
| 50 | 0.00 | |
| 63 | 0.03 | 0.03 |
| 80 | 0.04 | |
| 100 | 0.05 | |
| 125 | 0.11 | 0.12 |
| 160 | 0.20 | |
| 200 | 0.33 | |
| 250 | 0.45 | 0.47 |
| 315 | 0.63 | |
| 400 | 0.78 | |
| 500 | 0.91 | 0.92 |
| 630 | 1.06 | |
| 800 | 1.03 | |
| 1000 | 0.95 | 0.96 |
| 1250 | 0.89 | |
| 1600 | 0.88 | |
| 2000 | 0.89 | 0.88 |
| 2500 | 0.86 | |
| 3150 | 0.93 | |
| 4000 | 0.87 | 0.89 |
| 5000 | 0.88 | |

Equivalent sound absorption area per unit



N₁₀ = 11

| | |
|-----------------------------|-----------------------|
| ORIGINAL TEST REPORT | DATE OF REPORT |
| - | - |

