



PRODUKTDEKLARATION

LJUDABSORPTIONSAREA FÖR OBJEKT

Mätt och utvärderad enligt ISO 354 och ISO 20189


Producent:	Abstracta
Objekt:	Zen Pod Small
Storlek [mm]:	w=1200 h=2310 d=1200

Ekvivalent ljudabsorptionsarea per objekt (m² Sabine)

f(Hz)	Tersband	Oktavband
100	2.20	
125	3.40	2.80
160	2.70	
200	1.70	
250	1.40	1.50
315	1.20	
400	1.30	
500	1.80	1.60
630	1.80	
800	1.50	
1000	1.30	1.45
1250	1.40	
1600	1.30	
2000	1.20	1.20
2500	1.00	
3150	1.00	
4000	1.40	1.20
5000	1.40	

N₁₀ = 8.6

Ekvivalent ljudabsorptionsarea per objekt



ORIGINAL TESTRAPPORT

RAPPORTDATUM





PRODUKTDEKLARATION

TALREDUKTION


Mätt och utvärderad enligt ISO 23351-1

Producent:	Abstracta
Objekt:	Zen Pod Small
Storlek [mm]:	w=1200 h=2310 d=1200

Talreduktion

f(Hz)	Oktavband (dB)
125	15.5
250	25.5
500	32.2
1000	34.9
2000	36.6
4000	38.9
8000	39.7

$D_{S,A} = 31.2$ dB



ORIGINAL TESTRAPPORT

20230529.1 Speech Level Reduction

RAPPORTDATUM

2023-05-29

