



## PRODUCT DECLARATION

### SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189


<b>Producer:</b>	Abstracta
<b>Object:</b>	Zen Pod Medium
<b>Size [mm]:</b>	w=1200 h=2321 d=2320

#### Equivalent sound absorption area per unit (m<sup>2</sup> Sabine)

f(Hz)	Octave Band
125	3.00
250	3.90
500	6.90
1000	8.10
2000	7.70
4000	7.90

N<sub>10</sub> = 1.4

Equivalent sound absorption area per unit



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF REPORT</b>
-	-





# PRODUCT DECLARATION

## SPEECH LEVEL REDUCTION


Measured and evaluated according to ISO 23351-1

<b>Producer:</b>	Abstracta
<b>Object:</b>	Zen Pod Medium
<b>Size [mm]:</b>	w=1200 h=2321 d=2320

### Speech level reduction

f(Hz)	Octave Band (dB)
125	16.4
250	25.4
500	32.0
1000	34.4
2000	38.6
4000	41.9
8000	39.9

$D_{S,A} = 31.2$  dB



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF REPORT</b>
-	-

