



PRODUKTDEKLARATION

LJUDABSORPTIONSAREA FÖR OBJEKT

Mätt och utvärderad enligt ISO 354 och ISO 20189


Producent:	Abstracta
Objekt:	Zen Pod Large
Storlek [mm]:	w=2320 h=2310 d=2320

Ekvivalent ljudabsorptionsarea per objekt (m² Sabine)

f(Hz)	Tersband	Oktavband
100	4.40	
125	5.80	4.80
160	4.10	
200	3.20	
250	2.90	2.90
315	2.70	
400	3.40	
500	3.60	3.40
630	3.20	
800	2.90	
1000	3.40	3.20
1250	3.30	
1600	3.40	
2000	3.00	3.30
2500	3.30	
3150	3.50	
4000	3.80	3.80
5000	4.10	

N₁₀ = 3.1

Ekvivalent ljudabsorptionsarea per objekt



ORIGINAL TESTRAPPORT	RAPPORTDATUM
20230822.2 Sound Absorption	2023-08-22





PRODUKTDEKLARATION

TALREDUKTION


Mätt och utvärderad enligt ISO 23351-1

Producent:	Abstracta
Objekt:	Zen Pod Large
Storlek [mm]:	w=2320 h=2310 d=2320

Talreduktion

f(Hz)	Oktavband (dB)
125	15.3
250	26.2
500	29.8
1000	34.7
2000	38.8
4000	41.7
8000	39.5

$D_{S,A} = 30.1$ dB



ORIGINAL TESTRAPPORT

20230822.1 Speech Level Reduction

RAPPORTDATUM

2023-08-22

