



PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT


Measured and evaluated according to ISO 354 and ISO 20189

Producer:	Götessons
Object:	Casa Uno
Size [mm]:	w=1200 h=2300 d=1200

Equivalent sound absorption area per unit (m² Sabine)

f(Hz)	1/3 Octave Band	Octave Band
50	1.82	
63	1.49	1.50
80	1.33	
100	1.71	
125	1.40	1.60
160	1.65	
200	1.88	
250	1.07	1.50
315	1.62	
400	1.23	
500	1.28	1.30
630	1.36	
800	1.54	
1000	1.50	1.60
1250	1.67	
1600	1.94	
2000	2.25	2.30
2500	2.76	
3150	3.02	
4000	3.47	2.30
5000	3.87	

Equivalent sound absorption area per unit



N₁₀ = 7.8

ORIGINAL TEST REPORT	DATE OF REPORT
-	-





PRODUCT DECLARATION

SPEECH LEVEL REDUCTION


Measured and evaluated according to ISO 23351-1

Producer:	Götessons
Object:	Casa Uno
Size [mm]:	w=1200 h=2300 d=1200

Speech level reduction

f(Hz)	Octave Band (dB)
125	20.4
250	28.5
500	30.4
1000	34.6
2000	36.6
4000	40.6
8000	45.3

$D_{S,A} = 31.2$ dB



ORIGINAL TEST REPORT	DATE OF REPORT
-	-

