



PRODUCT DECLARATION

SOUND ABSORPTION AREA FOR OBJECT


Measured and evaluated according to ISO 354 and ISO 20189

| | |
|-------------------|-------------------|
| Producer: | Götessons |
| Object: | Plant Divider |
| Size [mm]: | w=320 h=800 d=820 |

Equivalent sound absorption area per unit (m² Sabine)

| f(Hz) | 1/3 Octave Band | Octave Band |
|-------|-----------------|-------------|
| 50 | 0.27 | |
| 63 | 0.25 | 0.30 |
| 80 | 0.38 | |
| 100 | 0.50 | |
| 125 | 0.68 | 0.76 |
| 160 | 1.10 | |
| 200 | 1.24 | |
| 250 | 0.91 | 1.00 |
| 315 | 0.92 | |
| 400 | 0.67 | |
| 500 | 0.70 | 0.70 |
| 630 | 0.73 | |
| 800 | 0.78 | |
| 1000 | 0.84 | 0.84 |
| 1250 | 0.90 | |
| 1600 | 0.93 | |
| 2000 | 1.08 | 1.10 |
| 2500 | 1.23 | |
| 3150 | 1.45 | |
| 4000 | 1.68 | 1.70 |
| 5000 | 1.92 | |

Equivalent sound absorption area per unit



N₁₀ = 14

| ORIGINAL TEST REPORT | DATE OF REPORT |
|----------------------|----------------|
| 4915-R1a | 2026-05-12 |

