



## PRODUCT DECLARATION


### SOUND ABSORPTION COEFFICIENT FOR SURFACE

Measured and evaluated according to ISO 354 and ISO 11654

<b>Producer:</b>	Abstracta
<b>Surface:</b>	Air-X (Closed)
<b>Total Construction Height:</b>	w = 0

#### Sound absorption coefficient

f(Hz)	Practical sound absorption coefficient ( $\alpha_p$ )
63	0.00
125	0.07
250	0.19
500	0.64
1000	0.92
2000	0.94
4000	0.91



$\alpha_w = 0.55$

<b>ORIGINAL TEST REPORT</b>	<b>DATE OF REPORT</b>
20200904.1	2023-04-23

