PRODUCT DECLARATION


SOUND ABSORPTION COEFFICIENT FOR SURFACE

Measured and evaluated according to ISO 354 and ISO 11654

Producer:	Abstracta
Surface:	Sky
Total Construction Height:	w = 0

Sound absorption coefficient

f(Hz)	Practical sound absorption coefficient (α_p)
63	0.00
125	0.33
250	0.65
500	0.85
1000	1.00
2000	1.00
4000	1.00



α_w = 0.9

ORIGINAL TEST REPORT	DATE OF REPORT
20180923	2018-09-23

Acoustic Facts Scandinavia AB
Kinnegatan 23, 531 33 Lidköping