



# PRODUCT DECLARATION


## SOUND ABSORPTION COEFFICIENT FOR SURFACE

Measured and evaluated according to ISO 354 and ISO 11654

<b>Producer:</b>	Abstracta
<b>Surface:</b>	Sahara
<b>Total Construction Height:</b>	w = 0

### Sound absorption coefficient

f(Hz)	Practical sound absorption coefficient ( $\alpha_p$ )
63	0.00
125	0.05
250	0.05
500	0.20
1000	0.15
2000	0.10
4000	0.15



$\alpha_w = 0.15$

<b>ORIGINAL TEST REPORT</b>	<b>DATE OF REPORT</b>
-	-

